



## ADDENDUM NO. 2

TO: ALL BIDDERS  
PROJECT: ITB PW 07-21 – 6<sup>th</sup> Street Area Stormwater Improvements  
BID TIME AND DATE: 3:00 PM LOCAL TIME, December 2, 2020 (NO CHANGE)

November 23, 2020

The following items are hereby incorporated into the project manual, procurement documents, contract documents, plans and specifications:

---

### ITEM NO. 1 – QUESTIONS RECEIVED AT PRE-BID MEETING AND LATER

Question 1 – Is there an estimated budget for this project?

Answer: The total amount currently *budgeted* for the project is \$750,750 for everything from engineering through construction. Due to a change in the scope of the project during engineering, it is anticipated that additional Surtax funds will be needed. The estimated cost of construction is over \$1 million. Surtax funding is available, but is subject to approvals by the Infrastructure Surtax Advisory Committee (ISAC) and the Board of County Commissioners.

---

Question 2 – Is the public aware of the work? Can you provide that flyer that went out to the public?

Answer: Yes, the public is aware of the work. A sample letter and attachment sheets prepared by the engineer are attached hereto as Exhibit "A."

---

Question 3 – Pay item for carport? Is there room to just move it back?

Answer: There is not room to move it back (to the east). Additional discussion/coordination is underway between the owner and the County regarding the disposition of the carport. Bidders are advised, for bidding

purposes, to bid the cost to temporarily remove and reinstall the carport in its current location.

---

Question 4 – Can we cut and patch road?

Answer: Cut and patching of crossings should be done in accordance with patch details shown on Sheet C-027. Cuts in areas to be milled and overlaid will not need to be patched and milled, as long as the cuts are properly maintained with graded aggregate base material and any potential runoff is appropriately contained with silt fencing.

---

Question 5 – Landscape allowance.

Answer: No replacement of trees, bushes and other plantings is anticipated. The landscape allowance is expected to cover the cost of irrigation repairs and replacement necessitated by damage from construction, and is recommended to be a lump sum of \$5,000 for bid purposes. See the revised bid tab, and sheet C-003 attached as Exhibit 'B.'

---

Question 6 – Asphalt pay item? Is it remove and replace?

Answer: Asphalt and driveway removal is included in the cost of the clearing and grubbing pay item. The asphalt pay item is for replacement only.

---

END OF QUESTIONS

RECEIPT OF THIS ADDENDUM SHALL BE ACKNOWLEDGED BY WRITING THIS ADDENDUM NUMBER AND DATE IN THE SPACE PROVIDED ON DOCUMENT 00410-8, 'ADDENDUM ACKNOWLEDGEMENT - ATTACHMENT A.'

/s/ Steven R. Schmidt  
Steven R. Schmidt  
Surtax Project Manager