



ADDENDUM 2

ITB TDD 49-19

Emerald Coast Convention Center

Restroom Renovations and Meeting Room Counters

Date of Issue: August 23, 2019

Bid Submittal Deadline: The Bid Date will be extending by one week.

New bid opening date is **SEPTEMBER 4, 2019 AT 3:15 P.M.**

This addendum incorporates:

Revise Addendum No. 1 Bid Question No. 2 response.

Q2. There are toilet partitions that are specified that are now discontinued?

*R2. The material is discontinued, not the partition system itself. Toilet partition material shall be StonePly Natural Stone "Bianco Carrara" or "Arabescato Carrara Marble" only.*